



### NFPA Code Inspection Frequency Chart

Type	Frequency	Code
Fire alarm - functional test	Annual	NFPA 72 Ch. 14
Fire alarm - visual inspection	Semiannual	NFPA 72 Ch. 14
Fire alarm - sensitivity	Every 2 years	NFPA 72 Ch. 14
Extinguishers	Annually	NFPA 10 Ch. 7
Kitchen suppression	Semiannually	NFPA 17A Ch. 8
Emergency/exit lighting	Annually	NFPA 101 7.9.3
Fire doors	Annually	NFPA 80 Ch. 5
Fire roll/shutter doors	Annually	NFPA 80 Ch. 5
Fire dampers	Every 4 years	NFPA 80 Ch. 19